



# TOLEDO FIRE & RESCUE DEPARTMENT



## C-43 Fuel Oil Tank Leaking - Domestic

### Emergency Manual

Date Revised: 02/01/2018

Last Modified: 09/27/2024 09:45

[Export C43 to PDF](#)

[Export -Entire C Manual- to PDF](#)

---

### Policy/Procedure

- 1.** If a domestic fuel oil tank is leaking, crewmembers shall first shut off the emergency switch to the burner.
- 2.** Fire personnel shall then close the oil supply valve to the burner.
- 3.** If available, crewmembers shall utilize an emergency tank repair kit to stop the leak.
- 4.** If the leak is serious, fire personnel shall shut off and/or remove all sources of ignition until all the oil can be picked up. If there is a floor drain present, it should be sealed off.
- 5. NOTE:** It is the owner's responsibility to remove/clean-spilled oil. Crew members shall not clean up spilled oil.
- 6.** The Incident Commander shall update Dispatch and direct Dispatch personnel to contact Environmental Services and/or the Sewer Department.

---

See Also:

---

Permanent link:

[https://www.tfrdpolicies.com/dokuwiki/doku.php?id=c\\_manual:c43](https://www.tfrdpolicies.com/dokuwiki/doku.php?id=c_manual:c43)

Last update: **09/27/2024 09:45**

